

Northbrook, Illinois • (847) 272-8800

Melville, New York • (631) 271-6200

Santa Clara, California • (408) 985-2400

Research Triangle Park,
North Carolina • (919) 549-1400

Camas, Washington • (360) 817-5500



CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 111501-AU2687

ISSUE DATE:

November 15, 2001

Page 1 of 1

Issued to:

Capstone Turbine Corporation
21211 Nordhoff Street
Chatsworth, CA 91311

Report Reference:


AU2687-November 15, 2001

This is to Certify that
representative samples of:Stationary Engine Generator Assemblies, MicroTurbine Generator, Model
Capstone 60 SA, C60 SA or Part No. 513207-xxx, where xxx may be any suffix
between 1 and 999.Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s)
indicated on this Certificate.

Standard(s) for Safety:

UL 2200 "Stationary Engine Generator Assemblies", First Edition dated
September 1, 1998.

Additional Information:

Units also comply with the applicable utility interactive requirements of UL 1741
"Inverters, Converters, and Controllers for Use in Independent Power Systems",
First Edition dated May 7, 1999.Only those products bearing the UL Listing Mark should be considered as being covered by UL's
Listing and Follow-Up Service.The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number
(may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.**LOOK FOR THE UL LISTING MARK ON THE PRODUCT**

Engineer:



Greg Okada

Underwriters Laboratories Inc.

Review Engineer:



Maggie Carroll

Underwriters Laboratories Inc.